

IDE 20 / IDE 30 / IDE 50 / IDE 60 / IDE 80

EN

ORIGINAL INSTRUCTIONS
OIL HEATER



Table of contents

Notes regarding the instructions	2
Safety	3
Information about the device	5
Transport and storage	7
Assembly and start-up	7
Operation	12
Available accessories	15
Errors and faults	16
Maintenance	17
Technical annex.....	19
Disposal	28
Declaration of conformity	28

Notes regarding the instructions

Symbols



Warning of electrical voltage

This symbol indicates dangers to the life and health of persons due to electrical voltage.



Warning of flammable substances

This symbol indicates dangers to the life and health of persons due to flammable substances.



Warning of hot surface

This symbol indicates dangers to the life and health of persons due to hot surface.



Warning

This signal word indicates a hazard with an average risk level which, if not avoided, can result in serious injury or death.



Caution

This signal word indicates a hazard with a low risk level which, if not avoided, can result in minor or moderate injury.

Note

This signal word indicates important information (e.g. material damage), but does not indicate hazards.



Info

Information marked with this symbol helps you to carry out your tasks quickly and safely.



Follow the manual

Information marked with this symbol indicates that the instructions must be observed.



Wear hearing protection

Information marked with this symbol indicates that you should wear hearing protection.

You can download the current version of the instructions via the following link:



IDE 20

<https://hub.trotec.com/?id=39787>



IDE 30

<https://hub.trotec.com/?id=42316>



IDE 50

<https://hub.trotec.com/?id=42317>




IDE 60

<https://hub.trotec.com/?id=42318>



IDE 80

<https://hub.trotec.com/?id=42319>



Safety

Read this manual carefully before starting or using the device. Always store the manual in the immediate vicinity of the device or its site of use.



Warning

Read all safety warnings and all instructions.

Failure to follow the warnings and instructions may result in electric shock, fire and/or serious injury.

Save all warnings and instructions for future reference.

This device must not be used by children and persons under 16 years of age.

Children shall not play with the appliance. Cleaning and user maintenance shall not be made by children under 16 years.



Warning

Do not use the device in rooms if persons are present who cannot leave the room independently and who are not under constant supervision.

- Do not use the device in potentially explosive rooms or areas and do not install it there.
- Do not use the device in aggressive atmosphere.
- Only put up the device in an upright, stable position on firm ground.
- Let the device dry out after a wet clean. Do not operate it when wet.
- Do not use the device with wet or damp hands.
- Do not expose the device to directly squirting water.
- Never insert any objects or limbs into the device.
- Do not cover the device during operation.
- Do not remove any safety signs, stickers or labels from the device. Keep all safety signs, stickers and labels in legible condition.
- Attention: In Germany, the Federal Emission Protection Directive applies. Do not operate the device for more than 3 months at the same place. Prior to planning the flue gas system, gather information about the national legislation and contact a responsible specialist.
- Do not sit on the device.
- This device is not a toy. Keep away from children and animals. Do not leave the device unattended during operation.
- Check accessories and connection parts for possible damage prior to every use of the device. Do not use any defective devices or device parts.

- Ensure that all electric cables outside of the device are protected from damage (e.g. caused by animals). Never use the device if electric cables or the power connection are damaged!
- The mains connection must correspond to the specifications in the Technical annex.
- Insert the mains plug into a properly fused mains socket.
- Observe the device's power input, cable length and intended use when selecting extensions to the power cable. Completely unroll extension cables. Avoid electrical overload.
- Before carrying out maintenance, care or repair work on the device, remove the mains plug from the mains socket. Hold onto the mains plug while doing so.
- Switch the device off and disconnect the power cable from the mains socket when the device is not in use.
- When positioning the device, observe the minimum distances from walls and other objects as well as the storage and operating conditions specified in the Technical annex.
- Make sure that the air inlet and outlet are not obstructed.
- Make sure that the suction side is kept free of dirt and loose objects.
- Do not place the device on combustible ground.
- Only transport the device in an upright position.
- Only use original spare parts, for otherwise safe and functional operation cannot be ensured.
- Do not use the heating device together with a programming device, a timer, a separate remote control system or any other device that automatically switches the heating device on, as there is a risk of fire if the heating device is covered or incorrectly positioned.

Intended use

The device was developed for the purpose of generating hot air and may only be used in roofed over outdoor areas or in well-ventilated interior spaces whilst adhering to the technical data.

The device is suited for heating large rooms such as tents, warehouses, workshops, construction sites, greenhouses or agricultural halls.

It is intended to be used without frequent site changes.

The device may only be used in rooms with sufficient fresh air supply and exhaust discharge.

The device must only be operated with EL (ultra-light) fuel oil, kerosene and diesel, however not with petrol, heavy fuel oil etc.

Foreseeable misuse

- Do not place any objects, e.g. clothing, on the device.
- Do not use this device in the vicinity of fuel, solvents, varnishes or other easily inflammable vapours or in rooms where these substances are stored.
- Do not use the device out of doors.
- The device must not be positioned or operated in areas with a high risk of fires or in potentially explosive atmospheres.
- Do not use the device out of doors, unless under a roof.
- The device must not be operated in rooms with an insufficient combustion air supply.
- Do not make any unauthorised modifications, alterations or structural changes to the device.

Personnel qualifications

People who use this device must:

- be aware of the dangers resulting from heat, fire hazard and insufficient ventilation when working with oil heaters.
- be aware of the dangers that occur when handling fuels such as EL fuel oil or diesel.
- have read and understood the instructions, especially the Safety chapter.

Safety devices

The device is equipped with an electronic flame and maximum temperature monitoring system working with a photo cell and a safety thermostat.

The electronic control unit regulates the start-up, stopping and safety shutdown times in case of malfunctions.

Personal protective equipment



Wear hearing protection

Wear appropriate hearing protection when working with the device.

Residual risks



Warning of electrical voltage

Work on the electrical components must only be carried out by an authorised specialist company!



Warning of electrical voltage

Before any work on the device, remove the mains plug from the mains socket!
Do not touch the mains plug with wet or damp hands.
Hold onto the mains plug while pulling the power cable out of the mains socket.



Warning of flammable substances

Handling fuels entails a risk of fire.
Take sufficient precautions when handling fuels such as fuel oil, kerosene or diesel.
Do not spill any diesel, kerosene or fuel oil! Do not inhale the vapours nor swallow any fuel! Avoid skin contact!



Warning of hot surface

Parts of the device, especially at the air outlet, become very hot during operation. There is a danger of burning and fire. Do not touch the device during operation!
During operation observe a safety distance of at least 3 m to the device front! Observe the minimum distance from walls or other objects according to the technical data!



Warning of hot surface

Parts of this appliance can become very hot and cause burns. Particular attention is to be paid when there are children or vulnerable persons present!



Warning of hot surface

Improper handling entails a risk of burning. Only use the device as intended!



Warning

Improper handling entails a risk of burning and electric shock.
Only use the device as intended!



Warning

Dangers can occur at the device when it is used by untrained people in an unprofessional or improper way!
Observe the personnel qualifications!



Warning

The device is not a toy and does not belong in the hands of children.



Warning

Risk of suffocation!
Do not leave the packaging lying around. Children may use it as a dangerous toy.



Warning

Improper installation entails a risk of fire.
Do not place the device on combustible ground.
Do not place the device on high-pile carpets.



Warning

The device must not be covered, there is an imminent fire hazard!

Behaviour in the event of an emergency

1. In an emergency, disconnect the device from the mains feed-in: Switch the device off and disconnect it from the mains.
2. Remove persons from the danger area.
3. Do not reconnect a defective device to the mains.

Overheating protection

The device is provided with a safety thermostat which is activated by overheating of the device (when exceeding the operating temperature).

Investigate the cause of overheating.

If the safety thermostat does not switch in the event of overheating, the overheating protection will be tripped. In that case the device switches off completely. If so, please contact the customer service to have the overheating protection replaced.

Information about the device

Device description

The indirectly fired oil heaters IDE 20, IDE 30, IDE 50, IDE 60 and IDE 80 serve the purpose of heating the room air so as to quickly heat large rooms.


The devices only run on EL fuel oil or diesel, they must not be used with petrol, heavy fuel oil etc.

The devices are oil heaters with indirect combustion to be installed in roofed outdoor areas or in rooms with a sufficient fresh air supply. The devices are equipped with an exhaust gas connection for the discharge of exhaust gases via the chimney.

The devices IDE 30, IDE 50, IDE 60 and IDE 80 are additionally equipped with a fuel filter and a Danfoss pump.

Functional principle

The device generates warmth by conveying the sucked-in, cold air past the enlarged area of the combustion chamber, the heat exchanger. The air to be heated is completely isolated from the combustion chamber, where the fuel is burned. The combustion products are discharged into the open air through a flue pipe. The sucked-in air is heated and fed back to the environment via the air outlet.






Device depiction

IDE 20

The side view of the operating elements shows the device IDE 20 by way of example.

IDE 30 / IDE 50 / IDE 60 / IDE 80

In addition, the devices IDE 30, IDE 50, IDE 60 and IDE 80 come with a fuel filter located at the side. The fuel tank cap (10) and the tank filling level indication (11) of the devices IDE 50, IDE 60 and IDE 80 are located at the rear.



No.	Designation
1	Combustion chamber housing
2	Flue pipe connection
3	Transport handle
4	Air inlet with protective grid
5	Fan and motor
6	Tank
7	Frame
8	Control panel
9	Wheel
10	Fuel tank cap
11	Tank filling level indication
12	Air outlet for hot air
13	External fuel filter (except for IDE 20)
14	Danfoss injection pump (for IDE 20: fuel pump)

Transport and storage

Note

If you store or transport the device improperly, the device may be damaged.

Note the information regarding transport and storage of the device.

Transport

To make the device easier to transport, it is fitted with wheels.

To make the device easier to transport, it is fitted with a carry handle.

To make the device easier to transport, it is fitted with a transport handle and wheels.

Before transporting the device, observe the following:

- Switch the device off.
- Hold onto the mains plug while pulling the power cable out of the mains socket.
- Do not use the power cable to drag the device.
- Allow the device to cool down sufficiently.
- Before transporting or moving the device, make sure that the tank cap is tightly closed.

While transporting the device, observe the following:

- Slightly lift the device by the transport handle until the rear support no longer touches the ground.
- Wheel the device to the desired position.

Storage

Before storing the device, proceed as follows:

- Hold onto the mains plug while pulling the power cable out of the mains socket.
- Allow the device to cool down sufficiently.

When the device is not being used, observe the following storage conditions:

- Store the device in a dry location and protected from frost and heat.
- Store the device in an upright position where it is protected from dust and direct sunlight.
- If required, use a cover to protect the device from invasive dust.

Assembly and start-up

Scope of delivery

- 1 x Oil heater
- 1 x Frame components
- 2 x Wheel
- 1 x Axle
- 1 x Carry handle
- 1 x Installation material
- 1 x Flue pipe connection
- 1 x Cable holder (IDE 30, IDE 50, IDE 60, IDE 80)
- 1 x manual

Unpacking the device

1. Open the cardboard box and take the device out.
2. Completely remove the packaging.
3. Fully unwind the power cable. Make sure that the power cable is not damaged and that you do not damage it during unwinding.

Assembly

Upon delivery the devices are already partially preassembled.


The wheels, axle and frame still need to be mounted.

The assembly procedure is described below using the device IDE 20 as example.

Assembling the wheels


Prior to initial start-up, the wheels and the axle must be attached to the frame. To do so, please proceed as follows:

1. Slide the axle through the openings at the frame.



2. Attach both wheels to the axle.
3. Attach the locking rings to the axle.

4. Fasten the wheel caps to the wheels.




Info

If necessary, the frame can be disassembled again (e.g. for storage). To remove the wheels from the axle, you can carefully loosen the wheel caps and locking rings by means of a slotted screwdriver.

Assembly of transport handle and frame


1. Place the device on the frame. Make sure that the holes for the screws are positioned flush above each other.
2. First, bolt the 4 small screws to the frame.
3. Screw the nuts to the screws from below.
4. Place the transport handle on the rear of the device.
5. Bolt the 4 large screws to the transport handle, device and frame.



Assembly of the cable holder (except for IDE 20)

The devices are supplied with a cable holder (except for the IDE 20). Please proceed as follows to assemble the cable holder at the device:

1. Hold the cable holder to be mounted up against the side of the transport handle.
2. Make sure that the cable holder is attached at the pre-drilled holes.
3. Use the screws, washers and nuts to fasten the cable holder as illustrated below:



Assembly of the exhaust line



Warning

Note that this device must not be put into operation unless there is an exhaust line mounted at the flue pipe connection!

Assembly of a closed exhaust line




Warning

Make sure that in every operating and weather condition a vacuum of > 0.1 mbar is created in the exhaust line. This vacuum guarantees a safe discharge of exhaust gases from the room. The exhaust line must be installed upward. There must be no bends or elbows in the first 3 metres of the exhaust line!

If the device is used in closed rooms and the combustion gases are discharged via a chimney, a fresh air supply of approx. $80 \text{ m}^3/\text{h}$ (air inlet opening approx. 0.5 m^2) must be ensured.

- Prior to planning the flue gas system, gather information about the national legislation and contact a responsible specialist (cf. DIN 18160 in Germany).
- Ensure an unimpeded and sufficient combustion air supply (e.g. by means of ventilation openings in doors, ceilings, windows, walls or via interconnected airways).
- Have the exhaust emission of the burner checked at regular intervals.


Below are some examples of good and bad exhaust gas discharge:



Assembly of a flue pipe (optional)


When the flue pipe is mounted to the flue pipe connection for the discharge of the exhaust gas, the device must only be operated in outdoor areas. Please observe the following:

- The flue pipe must not exceed a length of 1 m.
- Bends and elbows in the flue pipe are prohibited.
- If the device is used out of doors, a rain cap must be mounted to the end to prevent the penetration of rain water and dirt.
- The flue pipe must be designed in a way to prevent counter-pressure.
- To ensure failure-free operation the flue pipe must be installed upward.




Chimney duct

The following schematic representation should be considered when planning a chimney duct:



Wall duct

The following schematic representation should be considered when planning a wall duct:



	Designation		Designation
A	min. 2 m	1	flue pipe connection
B	min. 3 m	2	cleaning opening with explosion protection flap
C	as short as possible	3	outer wall
D	$\geq \varnothing 120 \text{ mm} / 150 \text{ mm}$	4	chimney – inside min. 20 x 20 cm
E	min. 1 m	5	wall duct with elbow min. 5°
		6	draught booster H-shaped

Positioning

A number of spatial and technical conditions have to be considered for the selection of the device's installation site. Non-observance may impair the proper functioning of the device or the accessories or can entail risks of personal injury and property damage.

The following is to be observed for positioning:

- Do not operate the device for more than 3 months at the same place. Prior to planning the flue gas system, gather information about the national legislation and contact a responsible specialist.
- The device may only be operated on roofed over surfaces.
- The device is to be set up in a stable position on incombustible ground.
- The device must be set up in close proximity to a chimney, an outer wall or on an open, ventilated surface.
- The device must be connected to a properly secured mains power socket.
- The room where the device is positioned must be sufficiently ventilated.


Ensure a sufficient fresh air supply, especially when there are people or animals in the same room with the device!

- The minimum distance between walls or other objects and the air outlet opening of the device must be at least 3 m (see figure).

The minimum distance between walls or other objects and the air inlet opening of the device must be at least 2 m (see figure).

There must be no walls or large objects near the device.

- The inlet and outlet openings must not be covered.
- There must be a sufficient number of fire extinguishers available.
- Avoid low or excess pressure in the installation space, since this could lead to combustion-related difficulties.



Start-up

- Check the scope of delivery of your device for completeness. If an accessory part is missing, please contact the Trotec customer service or the specialist dealer where you purchased the device.
- Check the device and its connection parts for potential damage.
- Observe the conditions described in the chapter Positioning.
- Install the exhaust system of the device in a technically correct manner. You can also connect the device to a chimney or an outer wall as illustrated in chapter Assembly.
- Connect the device to an external tank or jerrycan as described in the Assembly chapter.
- Check the device for its proper condition prior to start-up and at regular intervals during application.
- Check whether the characteristics of the power grid conform to those on the nameplate.
- Each time before you plug the mains plug into the mains socket and switch on the device, make sure that the fan is moving freely.
- Connect the mains cable to a properly secured socket (230 V / 50 Hz / 10 A). On construction sites, there must be a residual current device (RCD) installed upstream of the socket in accordance with national regulations (in Germany: VDE 0100/0105).

The device is now ready for operation.

Filling the tank



Warning of flammable substances


In order to prevent fires, make sure that there are no ignition sources near the tank.

The fuel tank cap (10) and the tank filling level indication (11) of the IDE 20 are located at the side of the device next to the control panel. In case of the IDE 30, IDE 50, IDE 60 and IDE 80 the fuel tank cap (10) and the tank filling level indication (11) are located at the rear.


The figures in the description below show the IDE 20 by way of example.

- ✓ Before attempting to fill the tank, wait until the device has cooled down completely.
 - ✓ Only use fuel suitable for the device (see technical data).
1. Position the device on firm, level and incombustible ground.

- Unscrew the fuel tank cap (10).



- Fill the tank. In doing so, observe the filling level indication (11). Stop filling the tank just before the red range.
- Screw the fuel tank cap (10) back onto the tank. Observe the recesses at the tank opening and the protrusions at the fuel tank cap. They must be aligned when attaching the fuel tank cap. Make sure that the fuel tank cap is firmly attached to avoid leakage.




Operation


The device may only be used by accordingly instructed persons.

Operating element

IDE 20



IDE 30 / IDE 50 / IDE 60 / IDE 80



No.	Designation
15	Rotary control thermostat
16	Operating light
17	Warning sign
18	ON/OFF switch
19	Connection for external thermostat
20	Target value indication
21	Room temperature indication

Switching the device on




Wear hearing protection.

Excessive noise can lead to hearing loss.

The device continues to operate until the desired room temperature is reached.

- Set the on/off switch (18) to position I.
⇒ The on/off switch (18) is illuminated.
- Set the rotary control thermostat (15) to the desired room temperature. This value should be higher than the current room temperature. Use the figure below as reference.
- Ensure a successful ignition.

Switching the oil heater on (IDE 30 / IDE 50 / IDE 60 / IDE 80)



Shutdown



Warning of electrical voltage

Do not touch the mains plug with wet or damp hands.

Note

Damage to the device due to overheating!

Never switch off the device by pulling the mains plug.
This may lead to overheating!

Switch off the device properly. Only remove the mains plug from the device once the fan motor has stopped completely.

IDE 20

1. Turn the rotary control thermostat (15) to minimum.
2. If necessary, regulate the external thermostat to a low temperature using the settings of the controller.
3. Wait for approx. 90 s until the fan motor has come to a complete standstill.
4. Switch the device off by setting the on/off switch (18) to position **0**.
⇒ The on/off switch (18) is no longer illuminated.
5. Secure the device against inadvertent switch-on by pulling the mains plug.
6. Allow the device to cool down completely.

IDE 30 / IDE 50 / IDE 60 / IDE 80

1. Switch the device off by setting the on/off switch (18) to position **0**.
⇒ The flame goes out and the fan continues to run for approx. 90 seconds in order to cool down the burner.
2. If you use a thermostat, switch off the device using the settings of the controller (e.g. by setting a lower temperature at the thermostat).
3. Wait for approx. 90 s until the fan motor has come to a complete standstill.
4. Secure the device against inadvertent switch-on by pulling the mains plug.
5. Allow the device to cool down completely.

Restart after troubleshooting

During initial start-up and after the fuel oil circuit has been drained completely, the fuel oil supply to the nozzle may be insufficient. In this case, the flame monitoring system will respond and the device will be blocked. Proceed as follows:

1. Wait for approx. 1 minute.
2. Switch the device on.

If the device is still not starting, proceed as follows:

1. Make sure that there is fuel left in the tank.
2. Please refer to the chapters General safety warnings and Errors and faults.

Available accessories

Accessories	IDE 20 Article number	IDE 30 Article number	IDE 50 Article number	IDE 60 Article number	IDE 80 Article number
Hose connector	-	Ø 300 mm 6.100.006.180	Ø 440 mm 6.100.006.179	Ø 440 mm 6.100.006.179	Ø 440 mm 6.100.006.179
External thermostat with 25 m cable	6.100.006.113	6.100.006.112	6.100.006.112	6.100.006.112	6.100.006.112
Exhaust gas pipe rigid, length 1 m	6.100.006.212	6.100.006.212	6.100.006.210	6.100.006.210	6.100.006.210
90° arc connection for exhaust gas pipe	6.100.006.218	6.100.006.218	6.100.006.216	6.100.006.216	6.100.006.216
Exhaust gas pipe rain cover	6.100.006.224	6.100.006.224	6.100.006.222	6.100.006.222	6.100.006.222
Air hose Tronect SP-C ¹	-	6.100.001.265	6.100.001.270	6.100.001.270	6.100.001.270
Connection kit for external oil tank	-	6.100.006.183	6.100.006.183	6.100.006.183	6.100.006.183
Adapter set tank kit – oil hose	-	7.210.000.003	7.210.000.003	7.210.000.003	7.210.000.003
Tank line with quick couplings, length 5 m	-	6.100.006.037 ²	6.100.006.037 ²	6.100.006.037 ²	6.100.006.037 ²
Fuel tank, 1,000 litres	-	6.100.006.011	7.210.000.011	7.210.000.011	7.210.000.011
Fuel tank, 3,000 litres	-	6.100.006.012	6.100.006.012	6.100.006.012	6.100.006.012

¹ Important: The effective length of the hose for the above devices is limited to a maximum of 4 m! Tronect hoses with a standard effective length of 7.6 m will result in a forced switch-off and must be shortened by the user to a max. effective length of 4 m for the application.

² in combination with adapter set tank kit – oil hose (required accessories)



Warning

Only use accessories and additional equipment specified in the instructions.

Using insertion tools or accessories other than those specified in the instructions may cause a risk of injury.

Errors and faults



Warning of electrical voltage

Tasks which require the device to be opened must only be carried out by authorised specialist companies or by Trotec.



Warning

Risk of injury due to improper repair!

Never try to make any modifications or repairs on the device.

Unauthorised modifications can lead to serious injuries or death.

Have a certified specialist workshop perform the repair work.

The device has been checked for proper functioning several times during production. If malfunctions occur nonetheless, check the device according to the following list.

The device does not start:

- Check the power connection.
- Check the on-site fusing.

Smoke and/or sparks are emitted during first use:

- This is not a fault. These phenomena disappear after a brief runtime.

Noise emission during ignition or cooling:

- This is not a fault. The metal parts of the device expand when heated and generate noise.

Sparks and/or flame may be issued from the device during ignition:

- This is not a fault. Air might have accumulated in the lines. Keep a safety distance to the device!

The flame in the combustion chamber does not ignite:

- Check the filling level of the tank. Refill fuel if the tank is empty (see chapter Maintenance).
- Check the fuel filter and the fuel pump for dirt. If it is dirty, please contact the customer service.
- Check the fuel for contaminations, e.g. dirt or water. If required, drain the fuel completely and fill in new fuel (see chapter Maintenance).
- Safety shutdown: if the flame dies during operation, the electronics and the oil pump will be switched off. Investigate the cause on the basis of the following criteria:
 - **For qualified personnel only!**
Check the ignition: The distance between the two ignition electrodes should be 4 to 5 mm.

The flame goes out during combustion:

- Make sure the air supply is unobstructed. If required, clean the air intake opening.
- Check the filling level of the tank. Refill with fuel if the tank is empty (see chapter Operation).
- Check the fuel filter and the fuel pump for dirt. If it is dirty, please contact the customer service.
- Check the fuel for contaminations and replace it if required.
- Power failure: In the event of a power failure the ignition is extinguished, the device switches off immediately. After a power failure the device will not restart automatically, it has to be started via the on/off switch.

There is a fuel leak:

- Check whether too much fuel was filled in. Drain the fuel if necessary, see chapter Draining the tank.
- Check the drain screw for tight fit and retighten it if necessary.
- Check the sealing at the drain screw and replace it if damaged.
- Check the fuel pump for leaks. If there are doubts about the proper condition of the fuel pump, please contact the customer service.

The device emits smoke or dust:

- Check the mains voltage.
- Check the fuel for contaminations and replace it if required.
- Check the tank for contaminations and drain it if required (see chapter Maintenance). Refill with clean fuel.

The flame emerges from the air outlet:

- Check the mains voltage.
- Check the fuel for contaminations and replace it if required.
- Check the tank for contaminations and drain it if required (see chapter Maintenance). Refill with clean fuel.

Note

Wait for at least 3 minutes after maintenance and repair work. Only then switch the device back on.

The device still does not operate correctly after these checks:

Please contact the customer service. If necessary, bring the device to an authorised specialist electrical company or to Trotec for repair.

Maintenance

Maintenance intervals

Maintenance and care interval	before every start-up	as needed	at least every 2 weeks	at least every 4 weeks	at least every 6 months	at least annually
Check air inlets and outlets for dirt and foreign objects and clean if necessary	X					
Check air inlet grid(s) for dirt and foreign objects and clean if necessary	X		X			
Clean the exterior		X				X
Visually check the inside of the device for dirt		X		X		
Check for damage	X					
Check attachment screws		X				X
Test run						X

Maintenance and care log

Device type:

Device number:

Maintenance and care interval	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Check air inlets and outlets for dirt and foreign objects and clean if necessary																
Check air inlet grid(s) for dirt and foreign objects and clean if necessary																
Clean the exterior																
Visually check the inside of the device for dirt																
Check for damage																
Check attachment screws																
Test run																
Comments																

1. Date: Signature:	2. Date: Signature:	3. Date: Signature:	4. Date: Signature:
5. Date: Signature:	6. Date: Signature:	7. Date: Signature:	8. Date: Signature:
9. Date: Signature:	10. Date: Signature:	11. Date: Signature:	12. Date: Signature:
13. Date: Signature:	14. Date: Signature:	15. Date: Signature:	16. Date: Signature:

Activities required before starting maintenance



Warning of electrical voltage

Do not touch the mains plug with wet or damp hands.

- Switch the device off.
- Hold onto the mains plug while pulling the power cable out of the mains socket.
- Allow the device to cool down completely.



Warning of electrical voltage

Tasks which require the device to be opened must only be carried out by authorised specialist companies or by Trotec.

Cleaning the housing

Clean the housing with a soft, damp and lint-free cloth. Make sure that no moisture enters the housing. Protect electrical components from moisture. Do not use any aggressive cleaning agents such as cleaning sprays, solvents, alcohol-based or abrasive cleaners to dampen the cloth.


Wipe the housing dry after cleaning.

For a smooth operation of the device, the combustion chamber, the burner and the fan must be cleaned regularly.

1. Switch the device off as described in the Shutdown chapter.
2. Wait until the device has cooled down completely.

Cleaning after every 50 operating hours

1. Remove the fuel oil filter. Take out the filter insert and clean it with clean fuel oil.
2. Dismantle the upper part of the housing and clean the inner section and the fan blades with a cleaning fleece and, in case of heavy soiling, with a brass brush.
3. Check the condition of all cables and of the high-voltage plugs.
4. Dismantle the burner and clean its components with a brass brush.
5. Clean the electrodes. Check the distance of the electrodes and adjust if necessary (see figure).




6. Have the combustion chamber cleaned by the customer service.
7. Assemble the components in reverse order.

Draining the tank



Warning of flammable substances

In order to prevent fires, make sure that there are no ignition sources near the tank.



1. Provide for a suitable collection container.
2. Move the device to an elevated position.
3. As indicated in the figure use a wrench to open the screw at the bottom of the tank.
4. Drain the fuel into the collection container.
5. When no more fuel is discharged, seal the drain hole again.
⇒ Ensure the tight fit of the screw and, if required, replace the seal, for otherwise fuel might leak out uncontrollably.
6. Dispose of the fuel according to national regulations.

Technical annex

Technical data


Parameter	Value				
Model	IDE 20	IDE 30	IDE 50	IDE 60	IDE 80
Combustion	indirect	indirect	indirect	indirect	indirect
Air volume	600 m ³ /h	780 m ³ /h	2000 m ³ /h	2000 m ³ /h	2000 m ³ /h
Fan	axial fan	axial fan	axial fan	axial fan	axial fan
Nominal heat output	20 kW	30 kW	50 kW	60 kW	80 kW
Power consumption	230 W	230 W	900 W	900 W	900 W
Operating temperature	-20 °C to +45 °C	-20 °C to +45 °C	-20 °C to +45 °C	-20 °C to +45 °C	-20 °C to +45 °C
Relative humidity during operation	max. 80 % RH	max. 80 % RH	max. 80 % RH	max. 80 % RH	max. 80 % RH
Temperature increase ΔT	90 °C	95 °C	95 °C	90 °C	105 °C
Max. fuel consumption	1.9 l/h	2.8 l/h	4.8 l/h	5.7 l/h	7.6 l/h
Tank capacity	24 l	50 l	69 l	69 l	69 l
Flue pipe connection Ø	120	120	150	150	150
Input voltage	230 V / 50 Hz	230 V / 50 Hz	230 V / 50 Hz	230 V / 50 Hz	230 V / 50 Hz
Current consumption	1.1 A	1.5 A	3.2 A	3.2 A	3.3 A
Overheating protection	yes	yes	yes	yes	yes
Connection for external thermostat	yes	yes	yes	yes	yes
Sound pressure level (distance 1 m)	79 dB(A)	78 dB(A)	79 dB(A)	79 dB(A)	80 dB(A)
Weight (with empty tank)	22.5 kg	34.5 kg	59 kg	59 kg	59 kg
Dimensions (length x width x height)	840 x 450 x 695 mm	1107 x 498 x 766 mm	1365 x 550 x 985 mm	1370 x 560 x 995 mm	1370 x 560 x 995 mm
Minimum distance to walls or other objects	top 2 m rear 2 m sides 3 m front 3 m	2 m 2 m 3 m 3 m	2 m 2 m 3 m 3 m	2 m 2 m 3 m 3 m	2 m 2 m 3 m 3 m
Permitted fuel	EL fuel oil, diesel or kerosene	EL fuel oil, diesel or kerosene	EL fuel oil, diesel or kerosene	EL fuel oil, diesel or kerosene	EL fuel oil, diesel or kerosene




Wear hearing protection.

Excessive noise can lead to hearing loss.

Wiring diagram IDE 20




Wiring diagram IDE 30 / IDE 50 / IDE 60 / IDE 80



Overview of spare parts IDE 20

Note!

The position numbers of the spare parts differ from those describing the positions of the components mentioned in these instructions.




Spare parts list IDE 20

NO.	SPARE PART	NO.	SPARE PART	NO.	SPARE PART
1	Oil drain seal Ring	24	Power PCB	47	Fan
2	Oil drain screw	25	Bottom casing	48	Top cover
3	Fuel tank	26	Heat insulation casing	49	Chimney connector
4	Support	27	Chamber bracket	50	Side plate
5	Power cord	28	Combustion chamber	51	Wheel axle
6	Cable fastener	29	Hook	52	Feet pipe
7	Ignition transformer	30	Air inlet disc	53	Cotter pin
8	Bracket Of Ignition transformer	31	Photocell assembly bracket	54	Wheel
9	Fuel filter	32	Photocell assembly	55	Flat gasket
10	Sealing ring	33	Re-set thermostat bracket	56	Screw nut
11	Breath cover	34	Re-set thermostat	57	Steel pipe plug
12	Fuel tank cap	35	Flame plate	58	Handle
13	Sealing ring	36	Nozzle assembly	A-1	Socket
14	Tank cap shaft	37	Nozzle Adapter	A-2	Buckle
15	Oil inlet filter holder	38	Gas hose	A-3	Socket cap
16	Oil inlet filter	39	Oil hose	A-4	Plug
17	Oil leveler	40	Ignition needle	A-5	Line
18	Capillary thermostat	41	High voltage cable	A-6	Knob
19	Thermostat knob	42	Solenoid valve	A-7	Top cover
20	Light cover	43	Solenoid valve bracket	A-8	Capillary thermostat
21	On/off Switch	44	Air inlet grill	A-9	Bottom cover
22	Control panel	45	Motor support		
23	PCB bracket	46	Motor assembly		

Overview of spare parts IDE 30

Note!

The position numbers of the spare parts differ from those describing the positions of the components mentioned in these instructions.




Spare parts list IDE 30

NO.	SPARE PART	NO.	SPARE PART	NO.	SPARE PART
1	Oil drain seal ring	28	Heat insulation casing	55	Gear pump
2	Oil drain screw	29	Chamber bracket	56	Gear pump axle sleeve
3	Fuel tank	30	Combustion chamber	57	Solenoid valve cord
4	Power cord	31	Hook	58	Motor
5	Cable fastener	32	Photocell assembly bracket	59	Fan
6	Oil suction pipe	33	Air adjustment ring	60	Top bracket cover
7	Sealing ring	34	Photocell assembly	61	Top front cover
8	Oil return pipe	35	Re-set thermostat bracket	62	Chimney connector
9	Ignition transformer	36	Re-set thermostat	63	Side plate
10	Bracket of Ignition transformer	37	Nozzle assembly	64	wheel axle
11	Breath cover	38	Nozzle Adapter	65	Feet pipe
12	Fuel tank cap	39	Swirl disc	66	Cotter pin
13	Sealing ring	40	Nozzle base plate	67	Wheel
14	Tank cap shaft	41	Screw nut	68	Flat gasket
15	Oil inlet filter holder	42	Copper bend connector	69	Screw nut
16	Oil inlet filter	43	Ignition needle	70	Steel pipe plug
17	Oil leveler	44	Oil tube assembly	71	Handle
18	Thermostat knob	45	High voltage cable	72	Cable holder
19	Thermo cut-off adjust nut	46	Wind shield	A-1	Socket
20	Display window	47	Nozzle bend connector	A-2	Buckle
21	Display PCB2	48	Oil pipe	A-3	Socket cap
22	On/off switch	49	Filter	A-4	Plug
23	Control panel	50	Filter connector	A-5	Remote control cable
24	PCB support	51	Filter support	A-6	Bottom cover
25	Power PCB1	52	Air inlet grill	A-7	Fixing clip
26	Bottom casing	53	Motor support	A-8	Top cover
27	Air outlet	54	Fuel filter joint		

Overview of spare parts IDE 50 / IDE 60 / IDE 80

Note!

The position numbers of the spare parts differ from those describing the positions of the components mentioned in these instructions.



Overview of spare parts IDE 50 / IDE 60 / IDE 80

NO.	SPARE PART	NO.	SPARE PART	NO.	SPARE PART
1	Oil drain screw	29	Heat insulation casing	57	Gear pump
2	Oil drain seal ring	30	Casing support ring	58	Pump coupling
3	Fuel tank	31	Chamber bracket	59	Valve cord
4	Power cord	32	Combustion chamber	60	Motor
5	Cable fastener	33	Hook	61	Fan
6	Oil leveler	34	Photocell ass'y bracket	62	Top bracket cover
7	Oil inlet filter holder	35	Air adjustment ring	63	Top front cover
8	Oil inlet filter	36	Photocell ass'y	64	Chimney connector
9	Tank cap shaft	37	Thermostat bracket	65	Side plate
10	Sealing ring	38	Re-set thermostat	66	wheel axle
11	Fuel tank cap	39	Nozzle ass'y	67	Feet pipe
12	Breath cover	40	Nozzle Adapter	68	Cotter pin
13	Oil suction pipe	41	Swirl disc	69	Wheel
14	Sealing ring	42	Nozzle base plate	70	Flat gasket
15	Oil pipe union	43	Screw nut	71	Screw nut
16	Bottom casing	44	Elbow connection	72	Stell pipe plug
17	Body support pipe	45	Ignition needle	73	Handle
18	Ignition transformer	46	Oil tube assembly	74	Cable holder
19	Power PCB1	47	High voltage cable	A-1	Socket
20	PCB support	48	Air balance plate	A-2	Buckle
21	Control panel	49	Filter elbow connection	A-3	Socket cap
22	Support bracket	50	Oil pipe	A-4	Plug
23	On/off switch	51	Filter	A-5	Line
24	Display PCB2	52	Filter straight connection	A-6	Bottom cover
25	Display window	53	Filter support	A-7	Fixing clip
26	Fixing nut	54	Air inlet grill	A-8	Top cover
27	Thermostat knob	55	Motor support		
28	Air outlet cone	56	Fuel pipe joint		

Disposal

Always dispose of packing materials in an environmentally friendly manner and in accordance with the applicable local disposal regulations.



The icon with the crossed-out waste bin on waste electrical or electronic equipment stipulates that this equipment must not be disposed of with the household waste at the end of its life. You will find collection points for free return of waste electrical and electronic equipment in your vicinity. The addresses can be obtained from your municipality or local administration. You can also find out about other return options that apply for many EU countries on the website <https://hub.trotec.com/?id=45090>. Otherwise, please contact an official recycling centre for electronic and electrical equipment authorised for your country.

The separate collection of waste electrical and electronic equipment aims to enable the re-use, recycling and other forms of recovery of waste equipment as well as to prevent negative effects for the environment and human health caused by the disposal of hazardous substances potentially contained in the equipment.

Fuel oil

The fuel oil must be drained from the device and collected.

Fuels are to be disposed of according to the national regulations.

Declaration of conformity

Declaration of conformity in accordance with the EC Machinery Directive 2006/42/EC, Annex II, Part 1, Section A

We – Trotec GmbH – declare in sole responsibility that the product designated below was developed, constructed and produced in compliance with the requirements of the EC Machinery Directive in the version 2006/42/EC.

Product model / product: IDE 20, IDE 30, IDE 50

Product type: oil heater

Year of manufacture as of: 2022

Relevant EU directives:

- 2011/65/EU
- 2012/19/EU
- 2014/30/EU
- 2015/863/EU

Applied harmonised standards:

- EN 60335-2-102:2016

Applied national standards and technical specifications:

- EN 60335-1:2012/A1:2019
- EN 60335-1:2012/A14:2019
- EN 60335-1:2012/A2:2019
- EN 62233:2008
- EN IEC 55014-1:2021
- EN IEC 55014-2:2021
- EN IEC 61000-3-2:2019
- EN IEC 61000-3-2:2019/A1:2021
- EN 61000-3-3:2013
- EN 61000-3-3:2013/A1:2019

Manufacturer and name of the authorised representative of the technical documentation:

Trotec GmbH

Grebbeener Straße 7, D-52525 Heinsberg

Phone: +49 2452 962-400

E-mail: info@trotec.de

Place and date of issue:

Heinsberg, 8 July 2022

Joachim Ludwig, Managing Director

Declaration of conformity in accordance with the EC Machinery Directive 2006/42/EC, Annex II, Part 1, Section A

We – Trotec GmbH – declare in sole responsibility that the product designated below was developed, constructed and produced in compliance with the requirements of the EC Machinery Directive in the version 2006/42/EC.

Product model / product: IDE 60, IDE 80

Product type: oil heater

Year of manufacture as of: 2022

Relevant EU directives:

- 2011/65/EU
- 2012/19/EU
- 2014/30/EU
- 2015/863/EU

Applied harmonised standards:

- EN 60335-2-102:2016

Applied national standards and technical specifications:

- EN 60335-1:2012/A1:2019
- EN 60335-1:2012/A14:2019
- EN 60335-1:2012/A2:2019
- EN 62233:2008
- EN IEC 55014-1:2021
- EN IEC 55014-2:2021
- EN IEC 61000-3-2:2019
- EN IEC 61000-3-2:2019/A1:2021
- EN 61000-3-3:2013
- EN 61000-3-3:2013/A1:2019
- EN 61000-3-3:2013/A2:2021

Manufacturer and name of the authorised representative of the technical documentation:

Trotec GmbH

Grebbener Straße 7, D-52525 Heinsberg

Phone: +49 2452 962-400

E-mail: info@trotec.de

Place and date of issue:

Heinsberg, 8 July 2022



Joachim Ludwig, Managing Director

Trotec GmbH

Grebbener Str. 7
D-52525 Heinsberg

☎ +49 2452 962-400

☎ +49 2452 962-200

info@trotec.com

www.trotec.com